



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or **T S W**

BELGE NUMARASI : 14.31.34/TSE-9767
REFERENCE NUMBER OF LICENCE

BELGENİN VERİLİŞ TARİHİ : 21/01/2010
DATE OF ISSUE OF LICENCE

BELGENİN SON GEÇERLİLİK TARİHİ : 21/01/2011
LICENCE VALID UNTIL

BELGE SAHİBİ KURULUŞUN ADI : EAE ELEKTRİK ASANSÖR ENDÜSTRİSİ İNŞ. SAN. VE TİC. A.Ş.
NAME OF THE LICENCE HOLDER

BELGE SAHİBİ KURULUŞUN ADRESİ : AKÇABURGAZ MAH.119.SOK.NO:10 ESENYURT - İSTANBUL / TÜRKİYE
ADDRESS OF THE LICENCE HOLDER

ÜRETİM YERİ ADI : EAE ELEKTRİK ASANSÖR ENDÜSTRİSİ İNŞ. SAN. VE TİC. A.Ş.
NAME OF THE MANUFACTURER

ÜRETİM YERİ ADRESİ : ÇAKMAKLI MAH.2.CAD.119 SOK.NO:12 KIRAÇ/ İSTANBUL/ TÜRKİYE
ADDRESS OF THE MANUFACTURING PLACE

İPTAL EDİLEN BELGE NUMARASI (Varsa) :
INDICATION OF SUPERSEDED LICENCE (if any)


TESCİLLİ TİCARİ MARKASI : "EAE" TRADE MARK;
(REGISTERED TRADE MARK)

İLGİLİ TÜRK STANDARDI : TS EN 61537/26.6.2007
RELATED TURKISH STANDARD

SCOPE :

TS EN 61537/JUNE 2007"CABLE MANAGEMENT - CABLE TRAY SYSTEMS AND CABLE LADDER SYSTEMS"
CLAS C,METALLIC COATED,
CABLE TRAYS AND ACCESSORIES WITH INSTALLATION AND OPERATINGTEMPATURES BETWEEN,
-20 °C - + 120 °C (AS DECLARED BY THE FIRM)
RESISTANCE TO IMPACT=50 J,
8 CLASS (AGAINST CORROSION),
MADE OF SHEET METAL,
NORMAL DUTY-HEAVY DUTY
UK SERIES CABLE TRAY SYSTEMS (CABLE TRAY AND ACCESSORIES)
WIDTH; FROM 50 MM UP TO 600MM,
HEIGHT;FROM 40 MM UP TO 100 MM,
THICKNESS;FROM 0,8 MM UP TO 2 MM
CT SERIES CABLE TRAY SYSTEMS (CABLE TRAY AND ACCESSORIES)
WIDTH;FROM 50 MM UP TO 600 MM,
HEIGHT;FROM 40 MM UP TO 100 MM,




21.01/2010

Ömer SÖNMEZ
MANAGER OF THE TSE ISTANBUL PRODUCT
CERTIFICATION DEPT.



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ EKİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS APPENDIX

SCOPE of CERTIFICATE (14.31.34/TSE-9767 continue) : EAE ELEKTRİK ASANSÖR
ENDÜSTRİSİ İNŞ. SAN. VE TİC. A.Ş.

İLGİLİ TÜRK STANDARDI TS EN 61537/26.6.2007
RELATED TURKISH STANDARD

THICKNESS;FROM 1 MM UP TO 2 MM
-CABLE LADDER SYSTEMS AND ACCESSORIES
CLAS Y,METALLIC COATEED,
CABLE TRAYS AND ACCESSORIES WITH INSTALLATION AND OPERATING TEMPATURES BETWEEN,
-20 °C - + 120 °C (AS DECLARED BY THE FIRM)
RESISTANCE TO IMPACT=50 J,
8 CLASS (AGAINST CORROSION)
MADE OF SHEET METAL
NORMAL DUTY-HEAVY DUTY
KC SERIES CABLE LADDER SYSTEMS(CABLE LADDER AND ACCESSORIES)
WIDTH; FROM 100 MM UP TO 600MM,
HEIGHT;FROM 40 MM UP TO 100 MM,
THICKESS;FROM 1,8 MM UP TO 2 MM
KM SERIES CABLE LADDER SYSTEMS(CABLE LADDER AND ACCESSORIES)
WIDTH; FROM 100 MM UP TO 600MM,
HEIGHT;FROM 40 MM UP TO 100 MM,
THICKESS;FROM 1,8 MM UP TO 2 MM
UMK SERIES CABLE LADDER SYSTEMS(CABLE LADDER AND ACCESSORIES)
WIDTH; FROM 100 MM UP TO 500 MM,
HEIGHT;60 MM,
THICKNESS;FROM 0,8 MM UP TO 1,2 MM



Ömer SÖNMEZ
MANAGER OF THE TSE ISTANBUL PRODUCT
CERTIFICATION DEPT.